

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 232

Dated: 16/09/2025


It is certified that an inspection team headed by HARI RAM LAKKHAN

(Name of Officers with designation) from HARI RAM LAKKHAN, S.I

(Name of Department/ Office) inspected the NAGAR PARISHAD, BEAWAR

(Name & Address of the school) on BHANWAR LAL GOTHI PUBLIC SR. SEC. SCHOOL BEAWAR (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 2025-26

Signature with Seal: Name: Designation: 

Name &amp; Address of the Office / Department : .....

To

BHANWAR LAL GOTHI PUBLIC SR. SEC. SCHOOL

KRISHNA COLONY, BEAWAR DIST-BEAWAR  
(RAJ.)

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

  
 Secretary

 Bhanwarlal Gothi Public Sr.Sec.School  
 BEAWAR (Raj.)



 PRINCIPAL  
 Bhanwarlal Gothi Public Sr.Sec.School  
 BEAWAR-305901 (Raj.)

**OFFICE OF THE SUPERINTENDING CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY; AJMER (Raj)**

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No. Lab/Tech./25-26/ 108) Sample was not Collected Date: 23.9.2025  
 by Laboratory

To, Principal **Not for Legal Purpose** District:- Beawar  
 Bhanwar Lal Gothi Public, Sr. Sec. School Tehsil:- Beawar  
 Krishana Colony Beawar



Reference : Your Letter No :- Nil Dated :- 17.09.2025  
 Sample Collected by :- Vikash Kothari UDC

Date of Receipt :- 17.09.2025

Lab Sample No.	IS10500:2012		P-44
Source :	Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	Water Cooler
Source Location:			Bhanwar Lal Gothi, Public Sr. sec. School Krishana Colony
Town / Village			Beawar
Date of Collection →			17.09.2025
Date of Examination →			18.09.2025
Test Parameter ↓			Results ↓
1 pH Value	6.5 - 8.5	No Relaxation	7.67
2 Turbidity (NTU)	1	5	1.0
3 Colour (Hazen Units)	5	15	1.0
4 Odour	Agreable		Agreable
5 Total Alkalinity (as CaCO <sub>3</sub> ) mg/l	200	600	120
6 Total Hardness (as CaCO <sub>3</sub> ) mg/l	200	600	140
7 Chlorides as Cl <sup>-</sup> mg/l	250	1000	70
8 Fluorides as F <sup>-</sup> mg/l	1.0	1.5	0.2
9 Nitrate as NO <sub>3</sub> <sup>-</sup> mg/l	45	No Relaxation	2.2
10 Total Dissolved Solids(T.D.S.) mg/l	500	2000	380
11 Residual Chlorine mg/l	0.2	1.0	Nil
	Applicable only when water is Chlorinated		

Note: 1. The sample was not collected by this laboratory.  
 2. This Report is not for legal Purpose.

  
**Secretary**  
 Bhanwarlal Gothi Public Sr. Sec. School  
 BEAWAR (Raj.)

  
 Superintendent Chemist  
 P.H.E.D. Regional Lab., Ajmer  
  
**PRINCIPAL**  
 Bhanwarlal Gothi Public Sr. Sec. School  
 BEAWAR-305901 (Raj.)

**OFFICE OF THE SUPERINTENDING CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT, REGIONAL LABORATORY, AJMER**  
**REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER**

No. Lab/Tech(Bact)/2025-26/ 1070 Sample was not Collected  
by Laboratory

Date 23.9.2025

To,

Principal  
Bhanwarlal Gothi Public Sr Sec School  
Krishana Colony , Beawar

District :- Beawar  
Tehsil :- Beawar

**Not for Legal Purpose**

Reference : Your Letter No.- Nil Dated 17.09.2025  
Sample Collected by :- Sh Vikas Kothari UDC

Sr. No.	Lab Sample No.	Date & Time of Collection	Date of Examination	City / Village	Source & Location	Residual Chlorine (mg/L)	Total Coliform Organism MPN/100 ml.
1	B- 15	17.09.2025 12 00 noon	17.09.2025	Beawar	Water Cooler, Bhanwarlal Gothi Public Sr Sec School, Krishana Colony	-	Nil


Remarks

Satisfactory:- Lab Sample No. B-15  
Unsatisfactory:- Nil

Note 1. The sample was not collected by this laboratory  
2. This Report is not for legal Purpose.

(Dr. Archana Mathur)

Superintending Chemist  
P.H.E.D. Regional Lab.,Ajmer

  
**Secretary**  
Bhanwarlal Gothi Public Sr.Sec.School  
BEAWAR (Raj.)

  
**PRINCIPAL**  
Bhanwarlal Gothi Public Sr.Sec.School  
BEAWAR-305901 (Raj.)

